ಬೆಸ್ಕಂ
BESCOM

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ

CIN: U04010KA2002SGC030438

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Email : gmcom@bescom.co.in
Ph:080-22341177
No: BESCOM/D(T)/GM(M&C)/2025-26/ 524

Corporate Office,
BESCOM, K.R.Circle,
Bangalore – 560 001.
Date: 25/08/2025

Amendment No.1

Sub: Procurement of Electrostatic meters for replacement of MNR/ Faulty/ Burnt-out meters or for department purpose for a period of one year on rate contract basis extendable for another one year at discretion of BESCOM.

Ref: 1. Paper Notification dated:15.07.2025.
2. KPPP Enquiry No. BESCOM/2025-26/IND0107.
3. Pre-bid meeting held on 12.08.2025.

* * *

The following amendments pertaining to subject bid enquiry is herewith issued consequent to request from the prospective bidders and deliberations held during pre-bid meeting:

Sl. No	Document	Clause No.	As existing	As amended
1	**Technical Specification Single phase Whole current meters**	**Clause No.5.7 Communication Capability**	-	ix. Optical ports on meters shall be designed to be used with a magnetic head on an optical probe. These magnets help secure the probe to the meter's optical port, ensuring a stable connection for data communication.
2	**Conditions of Contract**	**Clause No.8.0 Replacement of defective meters**	The agency shall maintain sufficient buffer stock of meters for replacement of **MNR/faulty meters failed WGP.** The meters declared defective by the consignees and / or by meter testing lab shall be replaced by the supplier within 15 days on receipt of BESCOM request for replacement of **faulty meters failed WGP** up to the full satisfaction of the purchaser at the cost of supplier on information by purchaser/stores officer.	The agency shall maintain sufficient buffer stock of meters for replacement of **MNR/faulty/RTC failed/drift (as per IS) meters WGP.** The meters declared defective by the consignees and /or by meter testing lab shall be replaced by the supplier within 15 days on receipt of BESCOM request for replacement of **MNR/ faulty/ RTC failed/drift (as per IS)** meters WGP up to the full satisfaction of the purchaser at the cost of supplier on information by purchaser/stores officer. If drift is more than the allowable limit as per IS, the agency shall provide patch file to correct the drift. If drift is abnormal above the allowable limit the agency shall replace the meter.

All other terms & conditions for the subject tender remain unaltered.

(Yogesh.B.K)
General Manager (M&C),
BESCOM